

CA506 & UPS

AA. CA506

**NetAgentA**

Information

UPS Status

System Status

Remote Control

SMS Modem Status

NetFeeler

Configuration

Log Information

Management

System InformationUPS InformationNetwork StatusConnections Status

System Information

Hardware Version	HCA506	UPS Last Self Test	--
Firmware Version	3.11.CA506	UPS Next Self Test	--
Serial Number	3926119360	UPS Critical Load	80 %
System Name	UPS Agent	UPS Critical Temperature	70.0 °C(158.0 °F)
System Contact	Administrator	UPS Critical Capacity	10 %
Location	My Office		
System Time	2024/07/05 02:42:10		
Uptime	00:11:03		
Warning will be initiated 10 minute(s) before Scheduled Shutdown Event			
Send Email for Daily Report (No)			

Latest Events

[02:41:11] UPS has switched to battery power.
[02:36:26] Server address can not be resolved.
[02:29:06] Server address can not be resolved.

BB. UPS and Battery Status

**NetAgentA**

Information
UPS Status
System Status
Remote Control
SMS Modem Status
NetFeeler
Configuration
Log Information
Management

UPS Status

Battery Status

Temperature	26.0 °C (78.8 °F)
Battery Status	Battery Normal
Battery Capacity	77 %
Battery Voltage	40.5
Time on Battery	00:00:43
Estimated Battery Remaining Time	00:04:00
UPS Last Self Test	--
UPS Next Self Test	--

Rating: 38.46

00:00:43

Latest Events
[02:41:11] UPS has switched to battery power.
[02:36:26] Server address can not be resolved.
[02:29:06] Server address can not be resolved.

CC. UPS Event Log


NetAgentA

Latest Events

[02:41:11] UPS has switched to battery power.
 [02:36:26] Server address can not be resolved.
 [02:29:06] Server address can not be resolved.

Information

Configuration

Log Information

Event Log

Data Log

Battery Test Log

Management

Event Log

2024 7 All Events

Refresh Today Save

July 2024 6

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
30	1 0	2 0	3 2	4 0	5 4	6 0
			1 1		3 1	
7 0	8 0	9 0	10 0	11 0	12 0	13 0
14 0	15 0	16 0	17 0	18 0	19 0	20 0
21 0	22 0	23 0	24 0	25 0	26 0	27 0
28 0	29 0	30 0	31 0	1	2	3

July 2024

Events List Events census

[07-05 02:42:28]: Utility power has been restored.
 [07-05 02:41:11]: UPS has switched to battery power.
 [07-05 02:36:26]: Server address can not be resolved.
 [07-05 02:29:06]: Server address can not be resolved.
 [07-03 07:55:26]: Server address can not be resolved.
 [07-03 07:54:52]: UPS communication has been lost.

DD. UPS Data Log



NetAgentA

Latest Events

[02:36:26] Server address can not be resolved.
 [02:29:06] Server address can not be resolved.
 [07:55:26] Server address can not be resolved.

- Information
- Configuration
- Log Information
 - Event Log
 - Data Log
 - Battery Test Log
- Management

Data Chart
 Data Log
 Data Statistics

No.	Date/Time	Input Volt.(V)	Output Volt.(V)	Freq. (Hz)	Load(%)	Capacity(%)	Battery Volt.(V)	Cell Volt.(V)	Temp.(°C °F)
1	2024-07-05 02:40:42	110.2	120.0	59.9	0	100	45.8	2.29	26.0/78.8
2	2024-07-05 02:40:37	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8
3	2024-07-05 02:40:32	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8
4	2024-07-05 02:40:28	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
5	2024-07-05 02:40:23	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
6	2024-07-05 02:40:18	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
7	2024-07-05 02:40:13	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
8	2024-07-05 02:40:08	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
9	2024-07-05 02:40:04	110.0	119.7	60.0	0	100	45.8	2.29	26.0/78.8
10	2024-07-05 02:39:59	109.7	120.0	60.0	0	100	45.8	2.29	26.0/78.8
11	2024-07-05 02:39:54	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
12	2024-07-05 02:39:49	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
13	2024-07-05 02:39:44	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
14	2024-07-05 02:39:40	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8
15	2024-07-05 02:39:35	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
16	2024-07-05 02:39:30	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
17	2024-07-05 02:39:25	110.0	120.0	60.0	0	100	45.8	2.29	26.0/78.8
18	2024-07-05 02:39:20	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
19	2024-07-05 02:39:16	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
20	2024-07-05 02:39:11	110.2	120.0	60.0	0	100	45.8	2.29	26.0/78.8
21	2024-07-05 02:39:06	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8
22	2024-07-05 02:39:01	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8
23	2024-07-05 02:38:56	110.2	120.0	59.9	0	100	46.0	2.30	26.0/78.8
24	2024-07-05 02:38:51	110.0	120.0	59.9	0	100	45.8	2.29	26.0/78.8

Date of Datalog: 2024/07/05
 1 2 3 Go 1 Refresh Save