

CA506PB & TC-UPS

AA. CA506PB

NetAgentA

Latest Events
[07:02:51] Server address can not be resolved.
[13:09:19] In inverter mode
[10:26:05] Server address can not be resolved.

Information
UPS Status
System Status
Remote Control
SMS Modem Status
NetFeeler
Configuration
Log Information
Management

System Information | UPS Information | Network Status | Connections Status | ?

System Information

Hardware Version	HCA506
Firmware Version	3.11.CA506PB.1
Serial Number	3927209950
System Name	UPS Agent
System Contact	Administrator
Location	My Office
System Time	2025/04/16 05:15:13
Uptime	1 day(s) 23:18:18
Send Email for Daily Report (No)	

NetAgentA

Latest Events
[07:02:51] Server address can not be resolved.
[13:09:19] In inverter mode
[10:26:05] Server address can not be resolved.

Information
UPS Status
System Status
Remote Control
SMS Modem Status
NetFeeler
Configuration
Log Information
Management

UPS Status | Event / Timer | Summary | Contact Status | ?

Voltage Rating: 120.0	Frequency Rating: 60.0	Battery Voltage Rating: 48.0
-----------------------	------------------------	------------------------------

Battery Status
Battery Capacity 91 %
Battery Voltage 54.2 V
Temperature 27 °C (80.6 °F)

BB. Support NetFeeler



NetAgentA

Latest Events

[07:02:51] Server address can not be resolved.
 [13:09:19] In inverter mode
 [10:26:05] Server address can not be resolved.

Information

- UPS Status
- System Status
- Remote Control
- SMS Modem Status
- NetFeeler

Configuration

Log Information

Management

NetFeeler

NetFeeler Status

Environmental Temperature	27.3 C (81.1 F)	Security1 Status	Normal
Environmental Humidity	59 %	Security2 Status	Normal
Water Status	Normal	Security3 Status	Normal
Gas Status	Normal	Security4 Status	Normal
Smoke Status	Normal	Security5 Status	Normal
		Security6 Status	Normal
		Security7 Status	Normal

[Reset Alarm](#)